



Vello Elektro BV  
 Typograaf 14  
 6921 VB Duiven NL  
 +31 (0)316 251500

V45.36.0552-S

A4

$I_{nA}$	63A	Date	Name	Remarks
$U_{nA}$	400V	23.05.2017	EP	
$f_n$ (AC)	50Hz	Check		
RDF	0,7	Adjustment		

Internal wiring H07V-K unless otherwise noted

According to NEN-EN-IEC-61439

Page  
1

Of  
1